

Disclaimer: Drawings produced by DANOSA UK should be considered non-scalable and for illustrative purposes only. Issued design principals form instructions for the installation of DANOSA UK materials only and should be considered as part of an overall design rather than in isolation. Product 'Technical Datasheets' are available for all DANOSA UK products and should be consulted in conjunction with all issued DANOSA UK installation instructions. Drawings are subject to copyright and should not be reproduced without permission.

Drawing Notes:
 The structural substrates should be primed in accordance with the project specification. Substrates shown in this drawing are for illustrative purposes only.


All membrane overlaps should be a minimum of 100mm to achieve a minimum 80mm full bond.

Note A:
 Where a full bond to the substrate is required, or where ESTERDAN 30 P ELAST SEMIADHESVIO is used as the underlay, GLASDAN 800 PERFORADO does not form part of the system.

Note B:
 The exposed core of the insulation must be protected if not bitumen compatible. A galvanised steel bracket is a common method shown for illustration purposes only.

Note C:
 Trim to be mechanically fastened at 200mm centres. Various profiles, colours and finishes are available. Profile shown for illustrative purposes only.

Note D:
 Fascia plate shown for illustrative purposes only. Vulnerable joint must be protected from wind-driven elements.



Drawing Number: DUK-B-(G)-242W	Revision: 00
Date Drawn: March 2017	Author: SL

Drawing Title:
 Parapet Kerb with Terminated with Pre-Formed Trim
 Bituminous Membranes - Warm Roof



DANOSA UK Limited
 Tel: 0845 074 0553 | www.danosa.co.uk | uktechnical@danosa.com